

**ERRATA SHEET FOR ANSI/ASHRAE ADDENDUM J**  
**ANSI/ASHRAE STANDARD 62.1-2022**  
**Ventilation and Acceptable Indoor Air Quality**

**May 14, 2024**

The corrections listed in this errata sheet apply to ANSI/ASHRAE Addendum j to ANSI/ASHRAE Standard 62.1-2022. The first printing is identified on the outside back cover as “4/24”.

**NOTICE:** ASHRAE now has a list server for Standing Standards Project Committee 62.1 (SSPC 62.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard is available. To sign up for the list server please visit **Project Committee List Servers** on the Standards and Guidelines section of the ASHRAE website at <https://www.ashrae.org/standards-research--technology/standards--guidelines/standards-activities/project-committee-list-servers>.

**Page    Erratum**

- 2    D1.2 Elevation Adjustment.** Revise Equations D-1a and D-1b as shown below. Corrections are highlighted in yellow.

**D1.2 Elevation Adjustment.** The elevation adjustment factor ( $C_z$ ) shall be calculated in accordance with Equation D-1a (I-P) or D-1b (SI).

$$C_z = 1 / (1 - Z \times 6.8754 \times 10^{-6})^{5.2559} \quad (\text{D-1a})$$

$$C_z = 1 / (1 - Z \times 2.25577 \times 10^{-5})^{5.2559} \quad (\text{D-1b})$$

where

$Z$  = outdoor air intake elevation above sea level, ft (m)