



ADDENDA

**ANSI/ASHRAE Addendum q to
ANSI/ASHRAE Standard 15-2022**

Safety Standard for Refrigeration Systems

Approved by ASHRAE and the American National Standards Institute on September 30, 2024.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2024 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 15

Cognizant TCs: 10.1, Custom Engineered Refrigeration Systems, and 9.1, Large Building Air-Conditioning Systems

SPLS Liaison: Kathleen Owen

ASHRAE Staff Liaisons: Ryan Shanley and Kai Nguyen

Gregory A. Scrivener*, <i>Chair</i>	James W. Dominik	Bill Kinast	John P. Scott
Danny M. Hale*, <i>Secretary</i>	Susanne Dormann*	KC Kolstad*	Stephen V. Spletzer*
Hugo Aguilar*	Mehdi M. Doura	Satheesh Kulankara*	Russell C. Tharp
Timothy D. Anderson	Taylor Duran	Travis Lancaster	Sriram Venkat
John Bade*	Glenn Friedman*	Kevin A. McFadden	James T. VerShaw
Julius A. Ballanco	Davi L. Goergen*	Neil Monson	John I. Vucci*
Wayne K. Borrowman*	Sivakumar Gopalnarayanan*	Jeffrey Newel*	Xudong Wang
Larry D. Burns	Craig Grider*	Roberto Pereira*	Christopher W. Williams*
Matthew M. Clark*	Connor A. Hayes	Jay Peters*	George A. Yaeger
Roy R. Crawford	Charles C. Hon	Justin M. Prosser	Jun Z. Yang
Wesley R. Davis*	Harshad V. Inamdar*	Douglas T. Reindl*	Chandra Yelamanchili
Thomas Deary	Phillip A. Johnson*	Brian J. Rodgers*	Hiroshi Yoh
Payam Delgoshaei	James G. Kendzel*	Vijaykumar Sathyamurthi*	

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2024–2025

Douglas D. Fick, <i>Chair</i>	Jaap Hogeling	Kenneth A. Monroe	Paolo M. Tronville
Adrienne G. Thomle, <i>Vice Chair</i>	Jennifer A. Isenbeck	Daniel H. Nall	Douglas K. Tucker
Hoy R. Bohanon, Jr.	Satish N. Iyengar	Philip J. Naughton	William F. Walter
Kelley P. Cramm	Phillip A. Johnson	Kathleen Owen	David P. Yuill
Abdel K. Darwich	Paul A. Lindahl, Jr.	Gwelen Paliaga	Susanna S. Hanson, <i>BOD ExO</i>
Drake H. Erbe	Julie Majurin	Karl L. Peterman	Wade H. Conlan, <i>CO</i>
Patricia Graef	Lawrence C. Markel	Justin M. Prosser	
William M. Healy	Margaret M. Mathison	Christopher J. Seeton	

Ryan Shanley, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum q addresses the use of the term “system” by clarifying the type of system in each use case. The most common update in the addendum is changing “system” to “refrigeration system” (see published Addendum c to Standard 15-2022). Changing “system” to “refrigeration system” references a defined term and is italicized. Additional changes include: “system” to “equipment” in some cases, “piping system” to “refrigeration system piping” and removing the word “refrigerating” when referring to a “machinery room.”

Informative Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum q to Standard 15-2022

Modify Section 2 as shown. The remainder of Section 2 remains unchanged.

2. SCOPE

[...]

2.3 This standard *shall not* apply to refrigeration systems using ammonia (R-717) as the *refrigerant*.

Informative Note: See ANSI/IIAR 2¹ for refrigeration systems ~~systems~~ using ammonia (R-717).

Modify Section 3 as shown. The remainder of Section 3 remains unchanged.

3. DEFINITIONS

[...]

companion valves (block valves): pairs of mating *stop valves* that allow sections of a refrigeration system ~~system~~ to be joined before opening these valves or separated after closing them.

[...]

limited charge system: a refrigeration system ~~system~~ in which, with the *compressor* idle, the *design pressure* will not be exceeded when the *refrigerant* charge has completely evaporated.

[...]

recovered refrigerants: refrigerants removed from a refrigeration system ~~system~~ in any condition without necessarily testing or processing them.

[...]

self-contained system: a complete, factory-assembled and factory-tested refrigeration system ~~system~~ that is shipped in one or more sections and has no *refrigerant*-containing parts that are joined in the field by other than *companion valves* or *block valves*.

[...]

system refrigerant charge (m_s): the total mass of *refrigerant* in an *independent circuit* of a refrigeration system ~~system~~, including both factory and field refrigerant charge.

[...]

three-way valve: a service valve for *dual pressure relief devices* that allows using one device while isolating the other from the refrigeration system ~~system~~, maintaining one valve in operation at all times.

[...]

Modify Section 5 as shown. The remainder of Section 5 remains unchanged.

5. REFRIGERATION SYSTEM CLASSIFICATION

[. . .]

5.2.1 High-Probability System. A *high-probability system* is any refrigeration system ~~system~~ in which the basic design or the location of components is such that a leakage of refrigerant from a failed connection, seal, or component will enter the occupied space.

[. . .]

5.2.2 Low-Probability System. A *low-probability system* is any refrigeration system ~~system~~ in which the basic design or the location of components is such that leakage of *refrigerant* from a failed connection, seal, or component cannot enter the *occupied space*.

[. . .]

5.3 Changing Refrigerant. Changes of *refrigerant* in an existing refrigeration system ~~system~~ to a *refrigerant* with a different *refrigerant designation* shall only be allowed where in accordance with Sections 5.3.1 through 5.3.4.

[. . .]

5.3.2 The change of *refrigerant* shall be in accordance with one of the following:

- a. Written instructions of the original equipment manufacturer
- b. An evaluation of the refrigeration system ~~system~~ by a registered design professional or by a *nationally recognized testing laboratory* that validates safety and suitability of the replacement *refrigerant*
- c. Approval of the authority having jurisdiction (AHJ)

5.3.3 Where the replacement *refrigerant* is classified into the same safety group, requirements that were applicable to the existing refrigeration system ~~system~~ shall continue to apply.

5.3.4 Where the replacement *refrigerant* is classified into a different safety group, the refrigeration system ~~system~~ shall comply with the requirements of this standard for a new installation, and the change of *refrigerant* shall require AHJ approval.

[. . .]

Modify Section 7 as shown. The remainder of Section 7 remains unchanged.

7. RESTRICTIONS ON REFRIGERANT USE

[. . .]

7.2.1 General. The *effective dispersal volume* identified in Section 7.3 into which *refrigerant* will disperse in the event of a release shall be calculated in accordance with this section. Volume calculations shall evaluate each space or *connected spaces* relevant to each refrigeration system. The smallest volume into which *refrigerant* disperses shall be used to determine the *refrigerant* quantity limit in the refrigeration system ~~system~~.

[. . .]

7.2.3.3 Connected Spaces via Ducted Air Distribution System. Where a refrigeration system or a part thereof is located within an air distribution duct system or in a space served by an air distribution duct system, the entire air distribution system shall be analyzed to determine the worst-case distribution of leaked refrigerant. The effective dispersal volume in which the leaked refrigerant disperses shall be used to determine the EDVC in the refrigeration system ~~system~~, subject to the criteria in the following subsections.

[. . .]

7.3.3* Industrial Occupancies and Refrigerated Rooms. *Industrial occupancies* and refrigerated rooms shall comply with the following conditions:

[. . .]

- g. *Refrigerant*-containing parts in refrigeration systems ~~systems~~ exceeding 100 hp (74.6 kW) compressor drive power, except *evaporators* used for refrigeration or dehumidification, *condensers* used for heating, control and *pressure relief valves* for either, *low-probability pumps*, and connecting *piping*, are located either in a *machinery room* or outdoors.

[. . .]

Figure 7-1 Refrigerant ~~system~~ charge limit compliance path—Part 1.

[...]

Figure 7-2 Refrigerant ~~system~~ charge limit compliance path—Part 2.

[...]

7.3.4.1 Single Circuit. For single-circuit refrigeration systems ~~systems~~, the releasable refrigerant charge (m_{rel}) shall be the system refrigerant charge, unless release mitigation controls are provided in accordance with Section 7.3.4.4.

7.3.4.2 Multiple Independent Circuits. For refrigeration systems ~~systems~~ with multiple *independent circuits*, the *releasable refrigerant charges* shall be the *refrigerant charges* in each *independent circuit*, unless release mitigation controls are provided in accordance with Section 7.3.4.4.

[...]

7.5.1.4 Recovered Refrigerants. Recovered refrigerants shall not be reused except in the refrigeration system ~~system~~ from which they were removed, or as provided in Sections 7.5.1.5 or 7.5.1.6. When contamination is evident by discoloration, odor, acid test results, or refrigeration system ~~system~~ history, recovered refrigerants shall be reclaimed in accordance with Section 7.5.1.6 before reuse.

7.5.1.5 Recycled Refrigerants. Recycled refrigerants shall not be reused except in refrigeration systems ~~systems~~ using the same refrigerant and lubricant designation and belonging to the same owner as the refrigeration systems ~~systems~~ from which they were removed. When contamination is evident by discoloration, odor, acid test results, or refrigeration system ~~system~~ history, recycled refrigerants shall be reclaimed in accordance with Section 7.5.1.6.

[...]

7.5.1.7 Mixing of Refrigerants. Refrigerants with different refrigerant designations shall only be mixed in a refrigeration system ~~system~~ in accordance with both of the following:

[...]

7.5.1.8 Refrigerant or Lubricant Conversion. The type of refrigerant or lubricant in a refrigeration system ~~system~~ shall not be changed without evaluation for suitability, notification to the AHJ and the user, due observance of safety requirements, and replacement or addition of signs and identification as required in Section 10.1.2.

7.5.1.9 Addition of Doors to Open Refrigerated Display Cases Containing Flammable Refrigerants. It is acceptable for doors to be added to open display cases containing flammable *refrigerants* only when in accordance with all of the following:

[...]

- c. Validation of safety and suitability of the addition of doors through one of the following:
 - 1. Written instructions of the original equipment *manufacturer* and approval of the AHJ
 - 2. Evaluation of the ~~system~~ equipment by a registered design professional and approval of the AHJ

[...]

7.7.1 Refrigerant Charge Limits. *Refrigerant charge shall* be limited as follows:

[...]

Exceptions to 7.7.1:

[...]

- 3. This restriction does not apply to refrigeration systems ~~systems~~ located in *machinery rooms* or outdoors.

[...]

7.8 Group A2 Refrigerants for Refrigeration Systems Other than Human Comfort. *High-probability systems* using Group A2 *refrigerants* for other than human comfort applications *shall* comply with this section. *Refrigeration systems* using Group A2 *refrigerants* shall be limited to *listed self-contained systems* containing no more than $0.459 \times LFL$ (lb), where *LFL* is in lb/1000 ft³ ($13 \times LFL$ [kg], where *LFL* is in kg/m³), provided that the refrigeration system ~~system~~ is installed in accordance with the listing and the *manufacturer's* installation instructions. Refrigeration systems containing more than $0.141 \times LFL$ (lb), ($4 \times LFL$ [kg]) in an *independent circuit* shall not be installed within 20 ft (6 m) of an open flame.

Modify Section 8 as shown. The remainder of Section 8 remains unchanged.

8. INSTALLATION RESTRICTIONS

[. . .]

8.3 Safe Access. A clear and unobstructed approach and space *shall* be provided for inspection, service, and emergency shutdown of *condensing units, compressor units, condensers, stop valves*, and other serviceable components of ~~refrigerating machinery~~. Permanent ladders, platforms, or portable access equipment *shall* be provided in accordance with the requirements of the authority having jurisdiction (AHJ).

[. . .]

8.9 Refrigerating Machinery Room, General Requirements. When a *refrigerating system* is located indoors and a *machinery room* is required by Section 7.4, the *machinery room shall* be in accordance with the following provisions.

[. . .]

8.9.2 Each ~~refrigerating machinery room~~ *shall* have a tight-fitting door or doors opening outward, self-closing if they open into the building and adequate in number to ensure freedom for persons to escape in an emergency. With the exception of access doors and panels in *air ducts* and air-handling units conforming to Section 8.9.3, there *shall* be no openings that will permit passage of escaping *refrigerant* to other parts of the building.

[. . .]

8.9.4 Access. Access to the ~~refrigerating machinery room~~ *shall* be restricted to authorized personnel. Doors *shall* be clearly marked, or permanent signs *shall* be posted at each entrance to indicate this restriction.

8.9.5 Each ~~refrigerating machinery room~~ *shall* contain a detector, located in an area where *refrigerant* from a leak will concentrate, that actuates an alarm and mechanical ventilation in accordance with Section 8.9.7 at a set point not greater than the *occupational exposure limit (OEL)* value as published in ASHRAE Standard 34³. For *refrigerants* that do not have a published *OEL* value in Standard 34, a set point determined in accordance with the *OEL* as defined by Standard 34 *shall* be *approved* by the AHJ. The alarm *shall* annunciate visual and audible alarms inside the ~~refrigerating machinery room~~ and outside each entrance to the ~~refrigerating machinery room~~. The alarms required in this section *shall* be of the manual reset type with the reset located inside the ~~refrigerating machinery room~~. Alarms set at other levels (such as *IDLH*) and automatic reset alarms are permitted in addition to those required by this section. The meaning of each alarm *shall* be clearly marked by signage near the annunciators.

Exception to 8.9.5: Detectors are not required when only *refrigeration systems* ~~systems~~ using R-718 (water) are located in the ~~refrigerating machinery room~~.

[. . .]

8.9.7 Mechanical ventilation referred to in Section 8.9.6 *shall* be by one or more power-driven fans capable of exhausting air from the *machinery room* at least in the amount given in the formula in Section 8.9.8. To obtain a reduced airflow for normal ventilation, multiple fans or multispeed fans *shall* be used. Provision *shall* be made for inlet air to replace that being exhausted. Openings for inlet air *shall* be positioned to avoid recirculation. Air supply and exhaust *ducts* to the *machinery room shall* serve no other area. The discharge of the air *shall* be to the outdoors in such a manner so as not to cause a nuisance or danger. The mechanical exhaust inlets *shall* be located in an area where *refrigerant* from a leak is likely to concentrate, in consideration of the location of the replacement air paths, *refrigeration systems* ~~refrigerating machines~~, and the density of the *refrigerant* relative to air.

[. . .]

8.9.8.1

[. . .]

A part of the ~~refrigerating machinery room~~ mechanical ventilation *shall* be

[. . .]

8.10 Machinery Room, Special Requirements. In cases *specified* in the rules of Section 7.4, a ~~refrigerating machinery room~~ *shall* meet the following special requirements in addition to those in Section 8.9:

[. . .]

- c. Walls, floor, and ceiling *shall* be tight and of noncombustible construction. Walls, floor, and ceiling separating the ~~refrigerating machinery room~~ from other *occupied spaces shall* be of at least one-hour fire-resistive construction.

[. . .]

- g. Remote control of the mechanical equipment in the ~~refrigerating machinery room~~ *shall* be provided immediately outside the *machinery room* door solely for the purpose of shutting down the equipment in an emergency. Ventilation fans *shall* be on a separate electrical circuit and have a control switch located immediately outside the *machinery room* door.

[. . .]

8.11.3 Walls, floor, and ceiling *shall* be tight and of noncombustible construction. Walls, floor, and ceiling separating the ~~refrigerating machinery room~~ from other *occupied spaces shall* be of at least one-hour fire-resistive construction.

[. . .]

8.11.7 Remote control of the mechanical equipment in the ~~refrigerating machinery room~~ *shall* be provided immediately outside the *machinery room* door solely for the purpose of shutting down the equipment in an emergency. Ventilation fans *shall* be on a separate electrical circuit and have a control switch located immediately outside the *machinery room* door.

8.11.8 Each ~~refrigerating machinery room~~ in accordance with Section 8.11 *shall* contain one or more *refrigerant detectors* in accordance with Section 8.11.9, with sensing element located in areas where *refrigerant* from a leak will concentrate, with one or more set points that activate responses in accordance with Section 8.11.10 for alarms and Section 8.11.11 for mechanical ventilation. Multiport-type devices *shall* be prohibited.

[. . .]

8.11.10.1 The alarm *shall* have visual and audible annunciation inside the ~~refrigerating machinery room~~ and outside each entrance to the ~~refrigerating machinery room~~.

8.11.10.2 The *refrigerant detector* set points *shall* activate an alarm in accordance with the type of reset in Table 8-1. Manual reset type alarms *shall* have the reset located inside the ~~refrigerating machinery room~~.

[. . .]

8.11.11.1 Mechanical ventilation referred to in Section 8.11.11 *shall* be in accordance with all of the following:

[. . .]

- d. Inlets to the exhaust *ducts shall* be located in an area where *refrigerant* from a leak will concentrate, in consideration of the location of the replacement supply air paths, refrigeration systems ~~refrigerating machines~~, and the density of the *refrigerant* relative to air.

[. . .]

8.11.11.2 Level 1 Ventilation. The ~~refrigerating machinery room~~ mechanical ventilation in Section 8.11.11.1 *shall* exhaust at an airflow rate not less than shown in Table 8-2.

8.11.11.3 Level 2 Ventilation. A part of the ~~refrigerating machinery room~~ mechanical ventilation referred to in Section 8.11.11.1 *shall* exhaust an accumulation of *refrigerant* due to leaks or a rupture of a *refrigerating system*, or portion thereof, in the *machinery room*. The *refrigerant detectors* required in accordance with Section 8.11.8 *shall* activate ventilation at a set point and response time in accordance with Table 8-1, at an airflow rate not less than the value determined in accordance with Section 8.11.11.4. When multiple *refrigerant designations* are in the *machinery room*, evaluate the required airflow according to each *refrigerating system*, and the highest airflow quantity *shall* apply. Ventilation reset *shall* be in accordance with the type of reset in Table 8-1. Manual-type ventilation reset *shall* have the reset located inside the ~~refrigerating machinery room~~.

[. . .]

8.12

[. . .]

G = the mass of *refrigerant* in the largest refrigeration system ~~system~~, any part of which is located in the *machinery room*, lb (kg)

Modify Section 9 as shown. The remainder of Section 9 remains unchanged.

9. DESIGN AND CONSTRUCTION OF REFRIGERATION EQUIPMENT AND SYSTEMS

9.2 Refrigeration System Design Pressure

[...]

9.2.1

[...]

- a. *Low sides* of all refrigeration systems systems: 80°F (26.7°C)
- b. *High sides* of all water-cooled or evaporatively cooled refrigeration systems systems: 30°F (16.7°C) higher than the summer 1% wet-bulb temperature for the location, as applicable, or 15°F (8.3°C) higher than the highest design leaving condensing water temperature, or 104°F (40°C), whichever is greatest
- c. *High sides* of all air-cooled refrigeration systems systems: 30°F (16.7°C) higher than the summer 1% design dry-bulb temperature for the location but not lower than 122°F (50°C)

[...]

9.2.1.2 Standby conditions are intended to include normal conditions that are capable of being attained when the refrigeration system system is not in operation (e.g., maintenance, shutdown, power failure). Selection of the *design pressure* for *low-side* components shall also consider pressure developed in the *low side* of the refrigeration system system from equalization, or heating due to changes in ambient temperature, after the refrigeration system system has stopped.

[...]

9.2.6

[...]

- c. Defrost, for refrigeration systems systems designed with defrost capability

[...]

9.2.6.4

[...]

- a. A pressure-relieving connection that will relieve excess pressure to a lower pressure part of the refrigeration system system

[...]

9.4.3.1

[...]

- a. *pressure relief device* to relieve hydrostatic pressure to another part of the refrigeration system system and

[...]

9.4.4 *Heat exchanger coils* located downstream, or upstream within 18 in. (460 mm), of a heating source and capable of being isolated shall be fitted with a *pressure relief device* that discharges to another part of the refrigeration system system in accordance with Section 9.4.3 or outside any enclosed space in accordance with Section 9.7.8. The *pressure relief device* shall be connected at the highest possible location of the heat exchanger or *piping* between the heat exchanger and its manual isolation valves.

Exceptions to 9.4.4:

[...]

2. A relief valve shall not be required on ~~self-contained~~ self-contained systems or *unit systems* if the volume of the *low side* of the refrigeration system system, which is shut off by valves, is greater than the specific volume of the *refrigerant* at critical conditions of temperature and pressure as determined Equation 9-1:

$$V_1/[W_1 - (V_2 - V_1)/V_{gc}] \text{ shall be greater than } V_{gc} \quad (9-1)$$

where

V_1 = *low-side* volume, ft³ (m³)

V_2 = total volume of the referigeration system system, ft³ (m³)

W_1 = total weight of *refrigerant* in the refrigeration system-system, lb (kg)

V_{gt} = specific volume of *refrigerant* vapor at 110°F (43.5°C), ft³/lb (m³/kg)
 V_{gc} = specific volume at *critical temperature* and *critical pressure*, ft³/lb (m³/kg)

[. . .]

9.4.6 Stop valves shall not be located between a pressure relief device and parts of the *refrigeration system* protected thereby. A three-way valve, used in conjunction with the dual relief valve requirements of Section 9.7.2.3, is not considered a stop valve.

9.4.7

- a. A parallel relief valve is installed that protects the *refrigeration system* or vessels.
- b. The *refrigeration system* or vessels being protected have been depressurized and are vented to the atmosphere.

9.4.8 *Pressure relief devices* shall be connected directly to the *pressure vessel* or other parts of the *refrigeration system* protected thereby. These devices shall be connected above the liquid *refrigerant* level and installed so that they are accessible for inspection and repair and so that they cannot be readily rendered inoperative.

[. . .]

9.5.1 Pressure Relief Valve Setting. Pressure relief valves shall start to function at a pressure not to exceed the design pressure of the parts of the *refrigeration system* protected.

Exception to 9.5.1: See Section 9.7.8.3 for relief valves that discharge into other parts of the *refrigeration system*.

9.5.2 Rupture Member Setting. *Rupture members* used in lieu of, or in series with, a relief valve shall have a nominal rated rupture pressure not to exceed the *design pressure* of the parts of the *refrigeration system* protected. The conditions of application shall conform to the requirements of *ASME Boiler and Pressure Vessel Code*¹⁵, Section VIII, Division 1, paragraph UG-127. The size of *rupture members* installed ahead of relief valves shall not be less than the relief valve inlet.

9.6 Marking of Relief Devices and Fusible Plugs

[. . .]

Exception to 9.6.1: Relief valves for *refrigeration systems* with *design pressures* of 15 psig (103.4 kPa gage) or less shall be marked by the *manufacturer* with the pressure setting capacity.

[. . .]

Exceptions to 9.7.2.3: A single relief valve is permitted on *pressure vessels* of 10 ft³ (0.285 m³) or more *internal gross volume* when all of the following conditions are met:

1. The relief valves are located on the *low side* of the *refrigeration system*.
2. The vessel is provided with shutoff valves designed to allow pumpdown of the *refrigerant* charge of the *pressure vessel*.
3. Other *pressure vessels* in the *refrigeration system* are separately protected in accordance with Section 9.7.2.

9.7.3 For *pressure relief valves* discharging into the *low side* of the *refrigeration system*, a single relief valve (not *rupture member*) of the required relieving capacity shall not be used on vessels of 10 ft³ (0.283 m³) or more *internal gross volume* except under the conditions permitted in Section 9.7.8.3.

[. . .]

9.7.6 The rated discharge capacity of a *pressure relief device* expressed in lb of air/min (kg of air/s) shall be determined in accordance with *ASME Boiler and Pressure Vessel Code*¹⁵, Section VIII, Division 1, paragraph UG-131. All pipe and fittings between the *pressure relief valve* and the parts of the *refrigeration system* it protects shall have at least the area of the *pressure relief valve* inlet area.

[. . .]

9.7.8.1 Discharging Location Interior to Building. Pressure relief devices, including fusible plugs, serving refrigeration systems shall be permitted to discharge to the interior of a building only when all of the following apply:

- a. The *refrigeration system* contains less than 110 lb (50 kg) of a Group A1 or A2L refrigerant.
- b. The *refrigeration system* contains less than 6.6 lb (3 kg) of a Group A2, B1, B2L, or B2 refrigerant.

- c. The ~~refrigeration system~~ refrigeration system does not contain any quantity of a Group A3 or B3 refrigerant.
- d. The ~~refrigeration system~~ refrigeration system is to be installed in a machinery room as required by Section 7.4.

[. . .]

9.7.8.2 Discharging Location Exterior to Building.

[. . .]

- a. The point of vent discharge shall be located not less than 15 ft (4.57 m) above the adjoining ground level.
Exception to (a): Outdoor ~~refrigeration systems~~ refrigeration systems containing Group A1 refrigerant shall be permitted to discharge at any elevation where the point of discharge is located in an access controlled area accessible to authorized personnel only.
- b. The point of vent discharge shall be located not less than 20 ft (6.1 m) from windows, building ventilation openings, pedestrian walkways, or building exits.
- c. For heavier-than-air refrigerants, the point of vent discharge shall be located not less than 20 ft (6.1 m) horizontally from below-grade walkways, entrances, pits, or ramps if a release of the entire ~~refrigeration system~~ refrigeration system charge into such a space would yield a concentration of refrigerant in excess of the refrigerant concentration limit (RCL). The direct discharge of a relief vent into enclosed outdoor spaces, such as a courtyard with walls on all sides, shall not be permitted if a release of the entire ~~refrigeration system~~ refrigeration system charge into such a space would yield a concentration of refrigerant in excess of the RCL. The volume for the refrigerant concentration calculation shall be determined using the gross area of the space and a height of 8.2 ft (2.5 m), regardless of the actual height of the enclosed space.

[. . .]

9.7.8.3 Internal Relief. Pressure relief valves designed to discharge from a higher-pressure vessel into a lower-pressure vessel internal to the ~~refrigeration system~~ refrigeration system shall comply with all of the following:

[. . .]

- b. The capacity of the pressure relief valve protecting the part of the ~~refrigeration system~~ refrigeration system receiving a discharge from a pressure relief valve protecting a higher-pressure vessel shall be at least the sum of the capacity required in Section 9.7.5 plus the mass flow capacity of the pressure relief valve discharging into that part of the ~~refrigeration system~~ refrigeration system.

[. . .]

9.8 Positive Displacement Compressor Protection. Every *positive displacement compressor* with a *stop valve* in the discharge connection shall be equipped with a *pressure relief device* of adequate size and pressure setting, as *specified* by the *compressor manufacturer*, to prevent rupture of the *compressor* or to prevent the pressure from increasing to more than 10% above the maximum allowable working pressure of any other component located in the discharge line between the *compressor* and the *stop valve* or in accordance with Section 9.7.5, whichever is larger. The *pressure relief device* shall discharge into the low-pressure side of the ~~refrigeration system~~ refrigeration system or in accordance with Section 9.7.8.

The relief devices shall be sized based on *compressor* flow at the following conditions:

- a. *Compressors* in single-stage ~~refrigeration systems~~ refrigeration systems and high-stage *compressors* of other ~~refrigeration systems~~ refrigeration systems. Flow shall be calculated based on 50°F (10°C) saturated suction temperature at the *compressor* suction.

[. . .]

- c. Low-stage *compressors* in ~~cascade systems~~ cascade refrigeration systems. For those *compressors* that are located in the lower-temperature stages of ~~cascade systems~~ cascade refrigeration systems, flow shall be calculated based on the suction pressure being equal to the pressure setpoint of the pressure relieving devices that protect the *low side* of the stage against overpressure.

[. . .]

9.9.1 When Required. Pressure limiting devices complying with Section 9.9 shall be provided for compressors on all ~~refrigeration systems~~ refrigeration systems operating above atmospheric pressure.

Exception to 9.9.1: Pressure limiting devices are not required for *listed* factory-sealed ~~refrigeration systems~~ refrigeration systems containing less than 22 lb (10 kg) of Group A1 refrigerant.

9.9.2 Setting. Pressure limiting devices shall be set in accordance with one the following:

- a. For *positive displacement compressors*:

1. When refrigeration systems systems are protected by a *high-side pressure relief device*, the *compressor's pressure limiting device* shall be set at or below 90% of the operating pressure for the *high-side pressure relief device*.
 2. When refrigeration systems systems are not protected by a *high-side pressure relief device*, the *compressor's pressure limiting device* shall be set at or below the refrigeration systems' systems' *high-side design pressure*.
- b. For *nonpositive displacement compressors*:
1. When refrigeration systems systems are protected by a *high-side pressure relief device*, the *compressor's pressure limiting device* shall be set at or below 90% of the operating pressure for the *high-side pressure relief device*.
 2. When refrigeration systems systems are protected by a *low-side pressure relief device* that is only subject to *low-side* pressure and is provided with a permanent relief path between the refrigeration systems' systems' *high side* and *low side*, with- out intervening valves, the *compressor's pressure limiting device* shall be set at or below the refrigeration systems' systems' *high-side design pressure*.

[...]

9.10.1.1 Refrigerant piping, valves, fittings, and related parts having a maximum internal or external *design pressure* greater than 15 psig (103.4 kPa gage) shall be *listed* either individually or as part of an assembly or a refrigeration system system by a *nationally recognized testing laboratory*, or shall comply with ASME B31.5¹⁷ where applicable.

[...]

9.10.2 Reuse of Piping Materials on Existing Refrigeration Systems. Reused pipe, fittings, valves, or other materials on existing ~~refrigerant systems~~ refrigeration systems being renovated or modified shall be clean and free of foreign materials and shall comply with the requirements of Section 9.10.

[...]

9.11.4.3 Soldered Joints. Joint surfaces shall be cleaned. A flux conforming to ASTM B813⁵⁷ shall be applied. The joint shall be soldered with a solder conforming to ASTM B32⁵⁸. Solder joints shall be limited to ~~refrigerant systems~~ refrigeration systems using Group A1 *refrigerant* and shall not exceed the pressure rating *specified* in Appendix I of ASME B16.22⁴⁵.

[...]

9.12.2.2 Shaft Ventilation. Refrigerant pipe shafts with refrigeration systems systems using only Group A2L or B2L refrigerants shall be naturally or mechanically ventilated. *Refrigerant* pipe shafts with one or more refrigeration systems systems using any Group A2, A3, B2, or B3 *refrigerant* shall be continuously mechanically ventilated and shall include a *refrigerant detector*. The shaft ventilation exhaust outlet shall comply with the discharge location requirement *specified* in Section 9.7.8.2.

[...]

- b. When active, mechanically ventilated shafts shall have a minimum air velocity in accordance with Table 9-12. *Makeup air* shall be provided at the inlet to the shaft for mechanically ventilated shafts. The mechanical ventilation shall either be continuously operated or, for pipe shafts containing only refrigeration systems systems using Group A2L or B2L *refrigerants*, activated by a *refrigerant detector*. *Refrigerant* pipe shafts utilizing a *refrigerant detector* shall have a set point not exceeding the *occupational exposure limit (OEL)* of the *refrigerant*. The detector, or a sampling tube that draws air to the detector, shall be located in an area where *refrigerant* from a leak will concentrate.

[...]

9.12.5 Stop Valves. *Stop valves* shall be installed in *specified* locations when required in accordance with Section 9.12.5.1 and 9.12.5.2. *Stop valves* shall be identified in accordance with Section 9.12.5.3. This requirement shall not apply to the following:

- a. Refrigeration systems systems that have a *refrigerant pump-out* function capable of storing the entire *refrigerant* charge in a receiver or heat exchanger
- b. Refrigeration systems systems that are equipped with provisions for pump out of the *refrigerant* using either portable or permanently installed *refrigerant* recovery equipment
- c. ~~Self-contained listed systems~~ Listed self-contained systems

[...]

9.12.5.2 Refrigerating Systems Containing More Than 110 lb (50 kg) of Refrigerant. In addition to *stop valves* required by Section 9.12.5.1, ~~refrigeration systems~~ *systems* containing more than 110 lb (50 kg) of *refrigerant* shall have *stop valves* installed in the following locations:

[. . .]

Stop valves shall not be required on the inlet of a receiver in a *condensing unit* or on the inlet of a receiver that is an integral part of the *condenser* or ~~refrigeration systems~~ *systems* utilizing *nonpositive displacement compressors*.

[. . .]

9.13.1 General. *Refrigerating systems* fabricated, assembled, or erected on the *premises* shall be tested to the applicable requirements of this section. Tests shall include both the *high sides* and *low sides* of each ~~refrigeration system~~ *system*. ~~Refrigeration system~~ *system* components that have been strength tested under pressure by the component *manufacturer*, fabricator, or assembler are not required to be strength tested again on the *premises* unless modified or repaired. *Listed* equipment not modified or repaired shall not be required to be strength tested on the *premises*. After installation and before being placed in operation, ~~refrigeration system~~ *system* components not previously strength tested shall be strength tested under pressure in accordance with Section 9.13.5. After successful completion of the required strength tests and before being placed in operation, ~~refrigeration system~~ *system* components and field installed connections shall be leak tested for tightness in accordance with Section 9.13.6.

Informative Note: ~~Refrigeration system~~ *system* components that are strength tested prior to field assembly include (but are not limited to), compressors, *condensers*, precharged linesets, *pressure vessels*, *evaporators*, *refrigerant* bulk storage tanks, safety devices, pressure gages, and control mechanisms

9.13.2* Exposure of Refrigerant Piping System. *Refrigerant piping* and joints installed on the *premises* shall be exposed for visual inspection and testing prior to being covered or enclosed.

9.13.3 Test Gases. The medium used for pressure testing the ~~refrigerant system~~ *refrigeration system* shall be one of the following inert gases: oxygen-free nitrogen, helium, argon, or premixed nonflammable oxygen-free nitrogen with a tracer gas of hydrogen or helium. For R-744 ~~refrigerant system~~ *refrigeration systems*, carbon dioxide shall be allowed as the test medium. For R-718 ~~refrigerant system~~ *refrigeration systems*, water shall be allowed as the test medium.

[. . .]

9.13.4 Field Test Apparatus. The means used to pressurize the ~~refrigeration system piping~~ *refrigerant piping system* shall have either a pressure limiting device or a pressure reducing device and a test pressure measuring device on the outlet side. The test pressure measuring device shall have an accuracy of $\pm 3\%$ or less of the test pressure and shall have a resolution of 3% or less of the test pressure

9.13.5 Refrigerant Piping System Strength Test. *Refrigerating system* components and *refrigerant piping* shall be tested in accordance with ASME B31.5 17 or this section. Separate tests for isolated portions of the ~~refrigeration system~~ *system* are permitted, provided that all required portions are tested at least once. Pressurize with test gas for a minimum of ten (10) minutes to not less than the lower of (a) the lowest design pressure for any ~~refrigeration system~~ *system* component or (b) the lowest value of set pressure for any pressure relief devices in the ~~refrigeration system~~ *system*. The design pressures for determination of test pressure shall be the pressure identified on the label nameplate of the condensing unit, compressor, compressor unit, pressure vessel, or other ~~refrigeration system~~ *system* component with a nameplate. A passing test result shall have no rupture or structural failure of any ~~refrigeration system~~ *system* component or refrigerant piping.

[. . .]

9.13.6.1 Leak Testing Protocol. After the time to complete the strength test, continue to pressure test in accordance with Section 9.13.5 for a minimum period as *specified* in Table 9-13. The ~~refrigeration system~~ *system* shall show no loss in pressure on the pressure measuring device during the pressure test. Calculation of the pressure differential based on a change in ambient temperature shall be permitted. A vacuum of 0.0097 psi (67 Pa) absolute or lower shall be achieved (0.0197. in Hg [32°F]; 500 microns Hg [0°C]; 500 microns). After achieving a vacuum, the ~~refrigeration system~~ *system* shall be isolated from the vacuum pump. The ~~refrigeration system~~ *system* pressure shall not rise above 0.029 psi (200 Pa) absolute (0.059 in. Hg [32°F]; 1500 microns Hg [0°C]; 1500 microns) for a minimum period as *specified* in Table 9-13.

Informative Note: The vacuum pump should gradually create a vacuum to avoid freezing of any moisture in the ~~refrigeration system piping~~ *system*.

9.13.7 Contractor or Engineer Declaration. The installing contractor or registered design professional of record *shall* issue a certificate of test, verifying strength test in accordance with Section 9.13.5 and leakage test in accordance with Section 9.13.6, to the AHJ for all refrigeration systems ~~system~~ containing 55 lb (25 kg) or more of *refrigerant*. The certificate *shall* give the test date, photograph of the pressure gage at the test pressure, *refrigerant designation*, test medium, and the field test pressure applied to the *high side* and the *low side* of the refrigeration system ~~system~~. The certification of test *shall* be signed by the installing contractor or registered design professional and *shall* be made part of the public record.

[. . .]

9.14.4 Liquid receivers, if used, or parts of a refrigeration system ~~system~~ designed to receive the refrigerant charge during pumpdown *shall* have sufficient capacity to receive the *pumpdown charge*. The liquid *shall not* occupy more than 90% of the volume when the temperature of the *refrigerant* is 90°F (32°C).

Informative Note: The receiver volume is not required to contain the total refrigeration system ~~system~~ charge but is required to contain the amount being transferred. If the environmental temperature is expected to rise above 122°F (50°C), the designer *shall* account for the specific expansion characteristics of the *refrigerant*.

[. . .]

9.15.3 All refrigeration systems ~~systems~~ shall have provisions to handle the refrigerant charge for service purposes. When required, there *shall* be liquid and vapor transfer valves, a transfer *compressor* or pump, and *refrigerant* storage tanks or appropriate valved connections for removal by a reclaim, recycle, or recovery device.

[. . .]

9.16.1.1 Testing Procedure. Tests *shall* be performed with dry nitrogen or another nonflammable, non-reactive, dried gas. Oxygen, air, or mixtures containing them *shall not* be used. The means used to build up the test pressure *shall* have either a *pressure limiting device* or a pressure reducing device and a gage on the outlet side. The *pressure relief device* *shall* be set above the test pressure but low enough to prevent permanent deformation of the refrigeration system's ~~system's~~ components.

Exceptions to 9.16.1.1:

[. . .]

3. Compressed air without added *refrigerant* is allowed for factory tests, provided the refrigeration system ~~system~~ is subsequently evacuated to less than 1000 microns (132 Pa) before charging with *refrigerant*. The required evacuation level is atmospheric pressure for refrigeration systems ~~systems~~ using R-718 (water) or R-744 (carbon dioxide) as the *refrigerant*.

[. . .]

Modify Section 10 as shown. The remainder of Section 10 remains unchanged.

10.1.3 Each entrance to a ~~refrigerating~~ *machinery room* *shall* be provided with a legible permanent sign, securely attached and easily accessible, reading “Machinery Room—Authorized Personnel Only.” The sign *shall* further communicate that entry is forbidden except by those personnel trained in the emergency procedures required by Section 10.6 when the *refrigerant* alarm, required by Section 8.9.5, has been activated.

[. . .]

10.2 Charging, Withdrawal, and Disposition of Refrigerants. No service containers shall be left connected to refrigeration systems ~~systems~~ except while charging or withdrawing refrigerant.

[. . .]

10.6 Responsibility for Operation and Emergency Shutdown. It *shall* be the duty of the person in charge of the *premises* on which a *refrigerating system* containing more than 55 lb (25 kg) of *refrigerant* is installed to provide a schematic drawing or panel giving directions for the operation of the system equipment at a location that is convenient to the operators of the ~~equipment~~.

Emergency shutdown procedures, including precautions to be observed in case of a breakdown or leak, *shall* be displayed on a conspicuous card located as near as possible to the *refrigerant compressor*. These precautions *shall* address

- a. instructions for shutting down the system equipment in case of emergency;
- b. the name, address, and day and night telephone numbers for obtaining service; and

- c. the names, addresses, and telephone numbers of all corporate, local, state, and federal agencies to be contacted as required in the event of a reportable incident.

When a ~~refrigerating~~ *refrigerating machinery room* is used, the emergency procedures *shall* be posted outside the room, immediately adjacent to each door.

The emergency procedures *shall* forbid entry into the ~~refrigerating~~ *refrigerating machinery room* when the *refrigerant* alarm required by Section 8.9.5 has been activated, except by persons provided with the appropriate respiratory and other protective equipment and trained in accordance with jurisdictional requirements.

[. . .]

Modify Appendix F as shown. The remainder of Appendix F remains unchanged.

INFORMATIVE APPENDIX F EMERGENCIES IN REFRIGERATING MACHINERY ROOMS

This standard specifies ~~refrigerating~~ *refrigerating machinery rooms* under some conditions to reduce risks from large *refrigerating systems* and large amounts of *refrigerant*. One purpose of the requirements is to warn of emergencies in the ~~refrigerating~~ *refrigerating machinery room*. The *refrigerant detector* required by Section 8.9.5 or 8.11.8 triggers alarms inside and outside the ~~refrigerating~~ *refrigerating machinery room*. Signage warns refrigeration technicians and bystanders not to enter when the alarm has activated.

This appendix provides guidance on integrating the minimum emergency warning and training requirements of this standard with measures often taken in occupational health and safety programs.

The requirements in the standard provide minimum protection to help prevent injury from ~~refrigerating~~ *refrigerating machinery room* accidents. Minimal conformance to the standard's specifications does not necessarily facilitate the convenient handling of incidents in the room. For example, if only the minimum protective steps are taken, refrigeration technicians may not reenter the *machinery room* after an alarm has sounded (to silence the alarm and repair any damage) without calling on the services of emergency responders (generally the local hazardous materials team). Many other approaches are possible, especially in facilities that prepare sophisticated emergency response plans.

F1. ALARM LEVELS

A *refrigerant* level above the *occupational exposure limit (OEL)* activates the alarms required by Section 8.9.5 or 8.11.10. If personnel working in the ~~refrigerating~~ *refrigerating machinery room* are not provided with and trained to use respiratory protection equipment appropriate for the *refrigerant* (such as canister respirators or self-contained breathing apparatus), they must leave the room immediately. Presence of *refrigerant* above the *OEL* does not by itself signal an emergency. Many routine service operations can create such levels. Local or national regulations often prescribe that steps be taken to protect the health and safety of personnel working in the *machinery room* when *refrigerant* concentrations rise above the *OEL*.

[. . .]

F2. ALTERNATE REFRIGERANT LEVEL MEASUREMENTS

The required alarms signal only that *refrigerant* was detected at concentrations above the *OEL*. Some facilities may find it useful to have multiple levels of alarm or to provide an instrument that indicates the actual *refrigerant* level (digital readout in parts per million of *refrigerant*). Selecting proper respiratory protection for technicians or other responders, as mentioned above, is one reason. This is perfectly acceptable, provided that the additional alarms or indicators are clearly distinguished from the main alarm. Bystanders should not be confused by the alarm arrangements.

The main alarm must be a manual-reset type as required per Section 8.9.5 or 8.11.10.2. It is unwise to rely on automatic detectors to announce that an event is over. A technician could not distinguish between an alarm that reset when the *refrigerant* concentration dropped (e.g., because ventilation fans controlled the incident) and one that reset because the *refrigerant detector* was damaged. In the latter case, anyone entering the ~~refrigerating~~ *refrigerating machinery room* might be entering a hazardous area. Alarms or indicators intended to communicate current conditions inside the refrigeration *machinery room* may, of course, be automatically resetting.

F3. REENTRY INTO REFRIGERATING MACHINERY ROOMS

Reentering an area during an emergency requires sophisticated equipment and training; many national and local regulations govern such activities. Prepositioning emergency response equipment (e.g., self-contained breathing apparatus) should be done only by arrangement with emergency responders, and any preposi-

tioned equipment should be clearly labeled for use by trained personnel only. Doing otherwise invites unauthorized use (or vandalism) by untrained personnel, with dangerous consequences.

Facilities should note, however, that the alarms required in this standard announce not that an emergency is occurring but that an abnormal situation is occurring. It may be acceptable for trained personnel to enter the ~~refrigerating~~ *refrigerating machinery room* to investigate the situation, repair minor leaks, reset alarms tripped in error, etc. Any personnel required to enter should be provided with appropriate personal protective equipment (especially respiratory protection, if needed) and should be trained to recognize an emergency situation requiring professional emergency response.

F4. EXAMPLE EMERGENCY PROCEDURES

As an example (and there are many other possibilities), consider a facility that wishes to use its own technicians to handle minor problems in the ~~refrigerating~~ *refrigerating machinery room*. The facility

- a. provides the *refrigerant* alarm required by Section 8.9.5 or 8.11.10, along with signage warning “Authorized Personnel Only. Stay Out When Refrigerant Alarm Sounds; Call Facilities Management Immediately.” This alarm triggers at the *OEL*.
- b. provides a digital readout of the current *refrigerant detector* reading outside the ~~refrigerating~~ *refrigerating machinery room*. A sign distinguishes the current-reading indicator from the alarm-activation indicator required by Section 8.9.5 or 8.11.10.
- c. provides the refrigeration technicians with appropriate respiratory protection suitable for use in an atmosphere containing *refrigerant* in concentrations below the *IDLH*, in accordance with all applicable national and local regulations.
- d. defines as “incidental” any *refrigerant* release that is not producing levels above the *IDLH* in the *machinery room*. (The ventilating system will render many potential releases incidental.)
- e. trains the technicians to leave the ~~refrigerating~~ *refrigerating machinery room* when the *refrigerant* alarm sounds. After donning appropriate respiratory protection (if necessary), they may reenter the *machinery room* to close valves, fix leaks, shut off alarms, etc., if and only if the current *refrigerant* level is below the *IDLH*. That is, technicians may reenter the room if the *refrigerant* release is incidental. If the level exceeds the *IDLH*, or the problem seems uncontrolled in the sense that it may unpredictably worsen or require a team of technicians to fix, they are to leave and call for emergency responders.
- f. coordinates emergency procedures with the local emergency response agencies in advance.

None of these steps contradicts the requirements of the standard, but the additional procedures significantly aid the facility's efforts to handle minor maintenance problems safely.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 180 Technology Parkway · Peachtree Corners, GA 30092 · www.ashrae.org

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.