

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1ap – Publication Draft. This proposed addendum clarifies the rules for air and water economizers for budget building design.

Addendum 90.1ap (I-P and SI Editions)

Proposed wording change to 11.4.3(e) and (f):

- e) *Budget building* systems as listed in Table 11.4.3A shall have outdoor air economizers or water economizers, the same as in the proposed building, in accordance with 6.3.1. The high limit shut-off shall be in accordance with Table 11.4.3D.
- f) Not Used.

**TABLE 11.4.3D
Economizer High Limit Shut-off**

Economizer Type	High Limit Shut-Off
Air	Table 6.3.1.1.3B
Water (Integrated)	When its operation will no longer reduce HVAC system energy
Water (Non-Integrated)	When its operation can no longer provide the cooling load