

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1w –Publication Draft. Proposed changes clarify the intended use of this additional interior lighting power allowance and provide editorial corrections.

Addendum 90.1w

9.3 Prescriptive Path

9.3.1.2.1 Additional Interior Lighting Power. An increase in the *interior lighting power allowance* is allowed when using the Space-by-Space Method for specific space functions as noted in Table 9.3.1.2. In all such spaces in which an additional lighting power allowance is taken, the additional power shall be allowed only if the specified lighting is installed. Additional power shall be used only for the specified *luminaires* and shall not be used for any other purpose or in any other space.

An increase in the *interior lighting power allowance* for space types noted in Table 9.3.1.2 as eligible for additional *interior lighting power allowance* is permitted:

- (c) for lighting equipment installed in retail spaces that is specifically designed and directed to highlight merchandise provided that the additional lighting power shall not exceed:
 - (1) 1.6 W/ft² times the area of specific display, or
 - (2) 3.9 W/ft² times the area of specific display for valuable merchandise, such as jewelry, fine apparel and accessories, china and silver, art, and similar items, where detailed display and examination of merchandise are important.