© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.



ADDENDA

ANSI/ASHRAE Addendum ch to ANSI/ASHRAE Standard 135-2020

A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee on June 28, 2024, and by the American National Standards Institute on June 28, 2024.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2024 ASHRAE

ISSN 1041-2336



© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

ASHRAE Standing Standard Project Committee 135
Cognizant TC: 1.4, Control Theory and Application
SPLS Liaison: Paul Lindahl

Coleman L. Brumley, Jr.*, Chair David Fisher David Robin* Scott Ziegenfus, Vice Chair Alexander Gurciullo* Frank Schubert Salvatore Cataldi*, Secretary Bernhard Isler Steven C. Sill* Nate Benes* Thomas Kurowski* Marcelo Richter da Silva Steven T Bushby* Shahid Naeem Ted Sunderland James F. Butler Frank Victor Neher* Lori Tribble Tyler Cove Michael Osborne* Grant N. Wichenko* Brandon Michael DuPrey* Scott Reed Christoph Zeller

ASHRAE STANDARDS COMMITTEE 2023–2024

Douglas D. Fick, Chair Paul A. Lindahl, Jr. Karl L. Peterman Kelley P. Cramm James D. Lutz Justin M. Prosser Abdel K. Darwich David Robin Julie Majurin Drake H. Erbe Lawrence C. Markel Christopher J. Seeton Paolo M. Tronville Patricia Graef Margaret M. Mathison Kenneth A. Monroe Douglas Tucker Jaap Hogeling Jennifer A. Isenbeck Daniel H. Nall William F. Walter Phillip A. Johnson Philip J. Naughton Susanna S. Hanson, BOD ExO Gerald J. Kettler Kathleen Owen Ashish Rakheja, CO Jay A. Kohler Gwelen Paliaga

Ryan Shanley, Senior Manager of Standards

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

^{*} Denotes members of voting status when the document was approved for publication

[This foreword, the table of contents, the introduction, and the "rationales" on the following pages are not part of this standard. They are merely informative and do not contain requirements necessary for conformance to the standard.]

FOREWORD

These modifications are the result of change proposals made pursuant to the ASHRAE continuous maintenance procedures and of deliberations within Standard Project Committee 135. The changes are summarized below.

135-2020ch-1 Changes to Clause 5 to address segmentation errors, p. 3

In the following document, language to be added to existing clauses of ANSI/ASHRAE Standard 135-2020 is indicated through the use of *italics* and deletions are indicated by strikethrough. Where entirely new subclauses are proposed to be added, plain type is used throughout. Only this new and deleted text is open to comment at this time. All other material in this document is provided for context only and is not open for public review comment except as it relates to the proposed changes.

The use of placeholders such as XX, YY, ZZ, X1, X2, NN, x, n, ? etc. should not be interpreted as literal values of the final published version. These placeholders will be assigned actual numbers/letters only after final publication approval of the addendum.

135-2020ch-1 Changes to Clause 5 to address segmentation errors

Rationale

Addendum 135-2012*bh* part 1 contained updates to handle two cases described in the rationale. Case 2 is valid for behavior in the IDLE state; however, Case 1 has two flaws and the state machine description itself contains flaws

The first flaw of Case 1 is in the function DuplicateInWindow described in clause 5.4.2.2 regarding the local variable receivedCount. In the scenario described in Case 1, the value of receivedCount is not actually the number of received message segments in the current Window and will not be zero as required in step (4) that was added for the scenario.

The second flaw of Case 1 is more important. The scenario described in Case 1 is flawed, because there is no efficient way for a receiving device to determine if retransmitted message segments are being retransmitted because of delays in message transport or because the last BACnet-SegmentACK-PDU it sent was lost. If the last BACnet-SegmentACK-PDU was lost, then the receiving device is required to send another BACnet-SegmentACK-PDU to allow the message sender to continue with the remainder of the message.

In addition to these two flaws related to Case 1, there is a flaw in the calling parameters where the function DuplicateInWindow is called. The first parameter in each case specifies the BACnet-SegmentACK-PDU rather than the message that is currently being processed. As a result, the function cannot be checking the received message segment if used as written.

[Change Clause 5.4.2.2]

5.4.2.2 Function DuplicateInWindow

The function "DuplicateInWindow" determines whether a valuemessage segment sequence-number, seqA, is within the range firstSeqNumber through lastSequenceNumber modulo 256, of successfully received message segments in the current incomplete Window. or if called at the start of a new Window and no new message segments have been received yet, it determines if the value seqA is within the range of the previous Window. This case does not require a segment acknowledge, because the message segments in the Window have not all been successfully received yet. Only the last message segment of a Window requires a segment acknowledge before the message is complete. Parameter initialSequenceNumber is the last sequence number within the previously completed Window. Parameter lastSequenceNumber is the sequence number of the last segment successfully received in order. All computations and comparisons are modulo 256 operations on unsigned eight-bit quantities.

function DuplicateInWindow(seqA, firstSeqNumberinitialSequenceNumber, lastSequenceNumber)

- (1) Set local variable receivedCount to lastSequenceNumber minus firstSeqNumberinitialSequenceNumber, modulo 256 which is the number of successfully received message segments in the current Window.
- (2) If receivedCount is greater than ActualWindowSizezero, then the first received segment for the current Window is out of order and no segments of the current Window have been successfully received, return FALSE.
- (3) If seqA minus firstSeqNumber initialSequenceNumber, modulo 256, is less than or equal to receivedCount, then the message segment is a duplicate within the current incomplete Window, return TRUE so that the message segment is ignored. This segment is located in a previous part of the current Window.
- (4) If receivedCount is zero and firstSeqNumber minus seqA, modulo 256, is less than or equal to ActualWindowSize, then return TRUE.
- (5)(4) Else the message segment is an out of order segment in the current Window not yet successfully received, return FALSE.

Example (not normative): if ActualWindowSize is equal to 4, then

DuplicateInWindow(0, 0, 1) returns TRUE

DuplicateInWindow(1, 0, 1) returns TRUE

DuplicateInWindow(2, 0, 1) returns FALSE

DuplicateInWindow(3, 0, 1) returns FALSE

[Change Clause 5.4.4.4]

5.4.4.4 SEGMENTED_CONF

[...]

DuplicateSegmentReceived

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256, and DuplicateInWindow('sequence-number' parameter of the BACnet-SegmentComplexACK-PDU, InitialSequenceNumber+1 modulo 256, LastSequenceNumber) returns a value of TRUE and DuplicateCount is less than Ndup,

then discard the BACnet-ComplexACK-PDU segment; restart SegmentTimer; increment DuplicateCount, and enter the SEGMENTED CONF state to receive the remaining segments.

TooManyDuplicateSegmentsReceived

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256, and DuplicateInWindow('sequence-number' parameter of the BACnet-SegmentComplexACK-PDU, InitialSequenceNumber+1 modulo 256, LastSequenceNumber) returns a value of TRUE and DuplicateCount is equal to Ndup,

then discard the BACnet-ComplexACK-PDU segment; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ack' = TRUE, 'server' = FALSE, 'sequence-number' = LastSequenceNumber, and 'actual-window-size' = ActualWindowSize; restart SegmentTimer; set DuplicateCount to zero; and enter the SEGMENTED_CONF state to receive the remaining segments.

SegmentReceivedOutOfOrder

If a BACnet-ComplexACK-PDU that has sufficient security parameters is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256, and DuplicateInWindow('sequence-number' parameter of the BACnet-SegmentComplexACK-PDU, InitialSequenceNumber+1 modulo 256, LastSequenceNumber) returns a value of FALSE,

then discard the BACnet-ComplexACK-PDU segment; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ack' = TRUE, 'server' = FALSE, 'sequence-number' = LastSequenceNumber, and 'actual-window-size' = ActualWindowSize; restart SegmentTimer; set InitialSequenceNumber = LastSequenceNumber; set DuplicateCount to zero; and enter the SEGMENTED_CONF state to receive the remaining segments.

[Change Clause 5.4.5.2]

5.4.5.2 SEGMENTED REQUEST

[...]

DuplicateSegmentReceived

If a BACnet-Confirmed-Request-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256, and DuplicateInWindow('sequence-number' parameter of the BACnet-SegmentACKConfirmed-Request-PDU, InitialSequenceNumber+1 modulo 256, LastSequenceNumber) returns a value of TRUE and DuplicateCount is less than Ndup,

then discard the BACnet-Confirmed-Request-PDU segment; restart SegmentTimer; increment DuplicateCount; and enter the SEGMENTED REQUEST state to receive the remaining segments.

TooManyDuplicateSegmentsReceived

If a BACnet-Confirmed-Request-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256, and DuplicateInWindow('sequence-number' parameter of the BACnet-SegmentACKConfirmed-Request-PDU, InitialSequenceNumber+1 modulo 256, LastSequenceNumber) returns a value of TRUE and DuplicateCount is equal to Ndup,

then discard the BACnet-Confirmed-Request-PDU segment; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ack' = TRUE, 'server' = TRUE, 'sequence-number' = LastSequenceNumber, and 'actual-window-size' = ActualWindowSize; restart SegmentTimer; set InitialSequenceNumber = LastSequenceNumber; set DuplicateCount to zero; and enter the SEGMENTED_REQUEST state to receive the remaining segments.

SegmentReceivedOutOfOrder

If a BACnet-Confirmed-Request-PDU that is secured with the same settings as the original PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256, and DuplicateInWindow('sequence-number' parameter of the BACnet-SegmentACKConfirmed-Request-PDU, InitialSequenceNumber+1 modulo 256, LastSequenceNumber) returns a value of FALSE,

then discard the BACnet-Confirmed-Request-PDU segment; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ack' = TRUE, 'server' = TRUE, 'sequence-number' = LastSequenceNumber, and 'actual-window-size' = ActualWindowSize; restart SegmentTimer; set InitialSequenceNumber = LastSequenceNumber; set DuplicateCount to zero; and enter the SEGMENTED_REQUEST state to receive the remaining segments.

[Add a new entry to History of Revisions, p. 1364]

(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard.)

HISTORY OF REVISIONS

		•••
1	26	Addendum ch to ANSI/ASHRAE Standard 135-2020
		Approved by ASHRAE on June 28, 2024; and by the American National Standards Institute on June 28, 2024.
		Changes to Clause 5 to correct segmentation errors.

© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 180 Technology Parkway · Peachtree Corners, GA 30092 · www.ashrae.org

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.