

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2024,
Safety Standard for Refrigeration Systems**

January 2, 2025

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2024. The outside back cover marking identifying the first printing is “Product code: 86938”

(Note: Additions are shown in underline and deletions are shown in ~~striketrough~~.)

Page Erratum

22 **7.6.4* Mechanical Ventilation. [...]**

a. Mechanical ventilation *shall* be provided that will remove leaked *refrigerant* from the space where *refrigerant* leaking from the *refrigeration system* is expected to accumulate. The space *shall* be provided with an exhaust or transfer fan. Fans used to exhaust air ~~exhaust air~~ from the space or transfer air to a separate indoor space *shall* comply with Equation 7-10:

46 **Informative Note:** Tables 9-1 through 9-6 are based on $H = 150 \text{ Btu}/(\text{ft}^2 \cdot \text{min})$ [28.4 kW/m²]. As stated in Section 9.7.5.4, the *relieving pressures* are based on the *pressure relief device set pressure* is equal to *design pressure*.

56 **9.13.6.1 Leak Testing Protocol. [...]** A vacuum of 0.00967 psi (66.7 Pa) absolute or lower *shall* be achieved (0.0197 in. of mercury [32°F]; 500 μm of mercury [0°C]; ~~500 μm~~).