

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 34-2019, ADDENDUM F
Designation and Safety Classification of Refrigerants**

June 14, 2024

The corrections listed in this errata sheet apply to Addendum f to ANSI/ASHRAE Standard 34-2019. The identifying footer of all number pages include the title “ANSI/ASHRAE Addendum f to ANSI/ASHRAE Standard 34-2019.”

Page Erratum

- 12 Table 4-2 Data and Safety Classifications for Refrigerant Blends.** Refrigerant Number 455A (g/m3) value to be changed from 7.9 to 79 as shown below. Changes are highlighted in yellow.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

Table 4-2 Data and Safety Classifications for Refrigerant Blends (Continued)

Refrigerant Number	Composition (Mass%)	(g/m3)
[...]		
455A	R-744/32/1234yf (3.0/21.5/75.5)	7.9 <u>79</u>
[...]		