

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2022, ADDENDUM b
Designation and Safety Classification of Refrigerants

January 2, 2025

The corrections listed in this errata sheet apply to Addendum b to ANSI/ASHRAE Standard 15-2022. The identifying footer of all number pages include the title “ANSI/ASHRAE Addendum b to ANSI/ASHRAE Standard 15-2022.”

Page Erratum

5 9.7.5.7 Internal Heat Sources Include SI unit conversion value
(*Note: Additions are shown in underline and deletions are shown in ~~striketrough~~.*)

Informative Note: Tables 9-1 through 9-6 are based on $H = 150 \text{ Btu}/(\text{ft}^2 \cdot \text{min})$ [28.4 kW/m²]. As stated in Section 9.7.5.4, the *relieving pressures* are based on the *pressure relief device set pressure* is equal to *design pressure*.